

City of Mississauga Department Comments

Date Finalized: 2022-10-26	File(s): B62.22
To: Committee of Adjustment	Ward: 7
From: Committee of Adjustment Coordinator	Meeting date:2022-11-03 1:00:00 PM

Consolidated Recommendation

The City has no objections to the application.

Application Details

The applicant requests the approval of the Committee to sever a parcel of land for the creation of a new lot. The parcel of land has a frontage of 16.37m (approx. 53.71ft) and an area of 747.60sq m (approx. 8047.10sq ft).

Recommended Conditions and/or Terms of consent

- Appendix A – Conditions of Provisional Consent

Background

Property Address: 2429 Hensall St

Mississauga Official Plan

Character Area: Cooksville Neighbourhood
Designation: Residential Low Density I

Zoning By-law 0225-2007

Zoning: R3- Residential

Other Applications: None

Site and Area Context

The subject property is located on the east side of Hensall Street, north of the intersection with Queensway East. It currently contains a single storey detached dwelling with an attached garage. Some vegetative elements are present throughout the property, and mature trees are located close to the rear property line. It has an approximate lot area of +/- 1,494.52m² (16,087ft²), which is notably larger than other residential properties in the area. The surrounding context includes residential uses to the west and employment uses to the east.

The applicant is proposing to sever the subject property to create a new lot.



Comments

Planning

Provincial Matters

The Provincial Policy Statement 2020 (PPS 2020) and Growth Plan for the Greater Golden Horseshoe promote efficient development and land use, directing the focus towards intensification and redevelopment. Both documents seek to promote development within built up areas and the efficient use of both land and infrastructure by introducing a more compact built form within already settled areas. The proposal represents an appropriate level of intensification within an existing neighbourhood that can be serviced with existing infrastructure, and is therefore consistent with the general directive in provincial policy.

Planning Act

Section 51 (24) of the *Planning Act* sets out the criteria for land division in the Province of Ontario. In evaluating such requests, the Committee needs to be satisfied that the proposal

meets not only the criteria set out under Section 51(24), but also municipal requirements identify in local legislation.

Staff comments concerning the application for consent request are as follows:

The subject property is located in the Cooksville Neighbourhood Character Area and is designated Residential Low Density I in Schedule 10 of the Mississauga Official Plan (MOP). The designation permits detached, semi-detached, and duplex dwellings. Section 9 of MOP promotes development with appropriate urban form and site design, regulating that such development is compatible with the existing site conditions, the surrounding context, and the landscape of the character area.

Staff are satisfied that the application is consistent with the official plan as the severed and retained lands will provide for adequately sized lots for residential dwellings, with no variances required for lot frontage or lot area. The proposed lot sizes are generally in line with other residential properties along Hensall Street and will not negatively impact the character of the street or the area's lot fabric. Furthermore staff have no concerns with the severance regarding the criteria set out in Section 51(24) of the Planning Act as the site is appropriately serviced and is suitable for the planned use of the property. Staff are therefore of the opinion that the application conforms to Section 51(24) of the Planning Act.

Comments Prepared by: Alexander Davies, Committee of Adjustment Planner

Appendices

Appendix 1 – Transportation and Works Comments

Should Committee see merit in the applicant's request we are providing the following conditions/requirements for Committee's consideration:

A. Items Required Prior to the Issuance of Final Consent

1. Overall Site Plan/Grading and Drainage Plan

The applicant's consulting engineer will be required to prepare an Overall Site Plan which is to include Grading and Drainage information. Sufficient details are to be shown to ensure grading compatibility with the adjacent lands and submit the grading and drainage proposal to this department for review/approval.

Upon the review of the Site Plan/Overall Grading and Drainage Plan it may be determined that catch basins may be required and satisfactory arrangements will have to be made for the construction of any required catch basins.

2. Municipal Address Requirement

Prior to the issuance of final consent, satisfactory arrangements are to be made with Corporate Services Department, Information Technology Division, Digital Services & Mobility Section, Geospatial Solutions Group for the creation of new municipal addresses for the severed and retained lands. For further information, please contact Susie Tasca at (905) 615-3200 ext. 3088 or susie.tasca@mississauga.ca.

For further information regarding the above noted comments, please contact Tony Iacobucci at (905) 615-3200 ext. 5129 or tony.iacobucci@mississauga.ca

B. GENERAL INFORMATION

1. Lot Grading and Drainage

We advise the applicant that issuance of any building permits for the new dwelling(s) will be subject to the owner submitting a certified lot grading and drainage plan to this Department for review/approval. The grading and drainage plan is to contain sufficient detail to ensure grading compatibility with the adjacent properties. In addition, the owner will be required to submit the applicable lot grading and municipal services protection deposits.

2. Servicing

All costs incurred in providing any service laterals will be the responsibility of the owner. The owner will also be responsible for all costs incurred for the required road reinstatement (if required). If the service connections are to be installed by a private contractor retained by the owner, issuance of an open cut permit will be subject to the owner depositing adequate securities with the City to guarantee proper road reinstatement.

3. Access

The applicant will be required to apply for Access Modification Permits prior to Site Plan Approval and/or Building Permit Issuance. We advise the applicant that all costs incurred in providing any new driveway entrance(s) to the subject lands or any modifications/reinstatement required, would be at cost to the owner. Driveway accesses shall maintain a 1.5m setback from aboveground features such as utilities and trees. We are also noting that should any utilities need to be relocated, all costs incurred will also be to the owner.

4. Storm Sewer Outlet

The storm sewer outlet for this site is the existing 900mm storm sewer on Hensall Street. The applicant is encouraged to design the basement elevation 1 metre above the obvert of the storm sewer on the street to eliminate the need for a sump pump.

Please note that in cases of a high groundwater table where a sump pump could run continuously if a sump pump was implemented, the applicants should consider raising the basement elevation to be at least 1.0 meter above the groundwater level. It is the owner's responsibility to satisfy themselves with these conditions as the City has no obligation to address any concerns with the operating conditions of private sump pump systems.

For further information please contact Walter Copping at (905) 615-3200 ext. 5831.

Comments Prepared by: Tony Iacobucci, Development Engineering Technologist

Appendix 2 – Zoning Comments

Zoning has no objection to the Consent application provided that the severed and retained lands comply with the provisions of Zoning By-law 0225-2007, as amended, with respect to, among other things, minimum lot frontage, minimum lot area, setbacks to the existing building(s), on site parking, etc., or alternatively, that any minor variance(s) is approved, final and binding and/or the demolition of any existing building(s) is complete.

We further advise that the proposed lot frontage is to be calculated in accordance with the following definition:

- The applicant is advised that Lot Frontage means the horizontal distance between the side lot lines and where these lines are not parallel means the distance between the side lot lines measured on a line parallel to and 7.5 m back from the front lot line.

Comments Prepared by: Amy Campbell, Planner-in-Training

Appendix 3 – Parks, Forestry & Environment

The Park Planning Section of the Community Services Department has reviewed the consent application and advises as follows.

Should the application be approved, Community Services wishes to impose the following condition:

1. The applicant shall provide a cash contribution of \$1875.99 for the planting of three (3) street trees on Hensall Circle. This figure is subject to the most recent Fees and Charges By-law at the time of payment and is therefore subject to change.

In addition, Community Services notes the following:

1. Payment for street tree fees and charges can be made at the Parks and Forestry customer service counter located at 950 Burnhamthorpe Road West in the form of a certified cheque, bank draft, or money order payable to the City of Mississauga. Please contact Nicholas Rocchetti regarding the Covid-19 interim payment process.
2. Prior to the issuance of building permits, cash-in-lieu for park or other public recreational purposes is required pursuant to Section 42 of the Planning Act (R.S.O. 1990, c.P. 13, as amended) and in accordance with the City's policies and by-laws.

Should further information be required, please contact Nicholas Rocchetti, Park Planning Assistant, Community Services Department at 905-615-3200 ext. 4659 or via email Nicholas.Rocchetti@mississauga.ca.

Comments Prepared by: Nicholas Rocchetti, Park Planning Assistant

Appendix 4 - Bell

Subsequent to review of the Severance Application by our local Engineering Department, it has been identified that Bell Canada will require a transfer of easement over these lands to protect existing aerial facilities, supply service to the properties, and to maintain service in the area. According to our records, Bell's aerial cable runs along the northeast property boundary as identified in the sketch provided.

Bell Canada would like to confirm that a blanket easement over the lands or a 3.0m wide corridor to be measured 1.5m on either side of the aerial cable, then to extend from the pole to a

minimum of 1.0m past any anchor installation to be measured 0.5m on either side of the guy, as can be accommodated, would satisfy our needs.

Since the easement is necessary in order to provide and maintain service to this area, all costs associated with this transaction are the responsibility of the landowner. Compensation should be set to the nominal amount of \$2.00 for the acquisition of these rights. Additionally, Bell Canada requires separate, registered postponements for any mortgages and certification of title.

We hope this proposal meets with your approval and request a copy of the Committee of Adjustments decision. We look forward to the owners' Solicitor contacting us with a draft reference plan and accompanying draft easement and LTTS documents for our approval prior to registration, along with an acknowledgement and direction for our execution.

Comments Prepared by: Carrie Gordon, Right of Way Associate

Appendix 5 - Region of Peel

Development Engineering: Camila Marczuk (905) 791-7800 x8230

Comment: Please note that severing the lands may adversely affect the existing location of the water and sanitary sewer services, if any exist. The result of this may require the applicant to install new water / sanitary servicing connections to either the severed or retained lands in compliance with the Ontario Building Code. The applicant may require the creation of private water / sanitary sewer servicing easements.

An upgrade of your existing service may be required. All works associated with the servicing of this site will be at the applicant's expense. For more information, please contact Servicing Connections at siteplanservicing@peelregion.ca

Any changes to the underground water or sanitary sewer will require review by the Region of Peel. Region of Peel Site Servicing connection approvals are required prior to the local municipality issuing building permit. For more information, please contact Servicing Connections at siteplanservicing@peelregion.ca

Conditions: Arrangements satisfactory to the Region of Peel, Public Works shall be made with respect to the location of existing and installation of new services and/or possible required private service easements.

Comments Prepared by: Patrycia Menko, Junior Planner

Appendix A – CONDITIONS OF PROVISIONAL CONSENT

SHOULD THE COMMITTEE GRANT A PROVISIONAL CONSENT, THE FOLLOWING IS A LIST OF THE RECOMMENDED CONDITIONS TO BE ATTACHED TO THE DECISION AND THESE CONDITIONS MAY BE REVISED BY THE COMMITTEE AT THE PUBLIC MEETING.

1. Approval of the draft reference plan(s), as applicable, shall be obtained at the Committee of Adjustment office, and; the required number of prints of the resultant deposited reference plan(s) shall be received.
2. An application amendment letter shall be received from the applicant or authorized agent confirming that the conveyed land shall be together with and/or subject to services easement(s) and/or right(s)-of-way, if necessary, in a location and width as determined by the Secretary-Treasurer based on written advice from the agencies having jurisdiction for any service or right for which the easement or right-of-way is required; alternatively, a letter shall be received from the applicant or authorized agent confirming that no services easement(s) and/or right(s)-of-way, are necessary.
3. A letter shall be received from the City of Mississauga, Manager of Zoning Plan Examination, indicating that the conveyed land and retained lands comply with the provisions of the Zoning By-law, or alternatively; that any variances are approved by the appropriate authorities and that such approval is final and binding.
4. A letter shall be received from the City of Mississauga, Transportation and Works Department, indicating that satisfactory arrangements have been made with respect to the matters addressed in their comments dated October 26, 2022.
5. A letter shall be received from the City of Mississauga, Community Services Department, indicating that satisfactory arrangements have been made with respect to the matters addressed in their comments dated October 26, 2022.
6. A letter shall be received from the Region of Peel, Development Services/Public Works, indicating that satisfactory arrangements have been made with respect to the matters addressed in their comments dated October 24, 2022.
7. A letter shall be received from Bell indicating that satisfactory arrangements have been made with respect to the matters addressed in their comments dated October 4, 2022.