

City of Mississauga Department Comments

Date Finalized: 2023-04-19 To: Committee of Adjustment From: Committee of Adjustment Coordinator	File(s): A739.22 Ward: 3
	Meeting date:2023-04-27 1:00:00 PM

Consolidated Recommendation

The City has no objections to the application. The applicant may wish to defer the application to ensure the accuracy of the requested variance and that additional variances are not required.

Application Details

The applicant requests the Committee to approve a minor variance to allow an existing driveway with a width of 7.00m (approx. 22.96ft) whereas By-law 0225-2007, as amended, permits a maximum driveway width of 6.00m (approx. 19.69ft) in this instance.

Background

Property Address: 3423 Cedar Creek Dr

Mississauga Official Plan

Character Area: Applewood Neighbourhood
Designation: Residential Low Density I

Zoning By-law 0225-2007

Zoning: R3- Residential

Other Applications: None

Site and Area Context

The subject property is located north-east of the Cawthra Road and Bloor Street intersection in the Applewood neighbourhood. It currently contains a detached dwelling with some landscaping and vegetative elements in the front yard. The property has a frontage of +/- 17.9m (58.7ft),

which is characteristic of other lots in the area. The surrounding area context is predominantly residential, consisting of detached dwellings on lots of similar sizes.

The applicant is proposing to modify the existing driveway, thereby requiring a variance for driveway width.



Comments

Planning

Section 45 of the *Planning Act* provides the Committee of Adjustment with the authority to grant relief from the requirements of a municipal zoning by-law. Approval of applications must meet the requirements set out under 45(1) and/or 45(2) (a) or (b) in the *Planning Act*.

Staff comments concerning the application of the four tests to this minor variance request are as follows:

The subject property is located in the Applewood Neighbourhood Character Area and is designated Residential Low Density II in Schedule 10 of the Mississauga Official Plan (MOP). Section 9.1 of the MOP states that driveway widths and associated setbacks should respect the identity and character of the surrounding context.

The applicant is proposing a driveway width of 7.00m (22.96ft). The planned character of the area is that of residential dwellings serviced by appropriately sized driveways that can accommodate the parking required by the zoning by-law for each property. The intent of the driveway width regulations in the by-law is to allow a driveway that can accommodate two vehicles parked side by side, with the remainder of the front yard being soft landscaped area. Staff are satisfied that the width will restrict the parking to no more than two vehicles across and maintains sufficient soft landscaping area to maintain the character of the surrounding area.

Staff are of the opinion that, as currently proposed, the driveway maintains the general intent and purpose of the zoning by-law, represents appropriate development of the subject property, and is minor in nature.

Comments Prepared by: Alexander Davies, Committee of Adjustment Planner

Appendices

Appendix 1 – Transportation and Works Comments

This department notes that with regard to the widened driveway within the municipal boulevard (the area between the municipal curb and property line) we would request that this area be reinstated with topsoil and sod should the application be modified to reflect a smaller driveway width within the subject property or if the application is not supported by the Committee.

Comments Prepared by: Tony Iacobucci, Development Engineering Technologist

Appendix 2 – Zoning Comments

In the absence of a Development application we are unable to confirm the accuracy of the information provided, or determine whether additional variance(s) may be required. It should be noted that a zoning review has NOT been completed. The applicant is advised that should they choose to proceed without zoning verification, a full zoning review may result in further variances being required in the future.

For scope of work that does not require Site Plan Approval/Building Permit/Zoning Certificate of Occupancy Permit, the applicant may consider applying for a Preliminary Zoning Review application. A detailed site plan drawing and architectural plans are required for a detailed zoning review to be completed. A minimum of 6-8 weeks is required depending on the complexity of the proposal and the quality of information submitted.

Comments Prepared by: Brooke Herczeg, Zoning Examiner

Appendix 3- Region of Peel Comments

Please apply previous comments.

Comments Prepared by: Patrycia Menko, Junior Planner