

# City of Mississauga Department Comments

Date Finalized: 2023-10-04	File(s): A347.23 Ward: 1
To: Committee of Adjustment	
From: Committee of Adjustment Coordinator	Meeting date:2023-10-12 1:00:00 PM

## Consolidated Recommendation

The City recommends that the application be deferred.

## Application Details

The applicant requests the Committee to approve a minor variance to allow a dwelling proposing:

1. An exterior side yard setback of 5.28m (approx. 17.32ft) whereas By-law 0225-2007, as amended, requires a minimum side yard setback of 6.00m (approx. 19.69ft) in this instance;
2. A height to the highest ridge of 9.47m (approx. 31.07ft) whereas By-law 0225-2007, as amended, permits a maximum height of 9.00m (approx. 29.53ft) in this instance;
3. An eaves height of 7.112m (approx. 23.33ft) whereas By-law 0225-2007, as amended, permits a maximum height of 6.40m (approx. 21.00ft) in this instance; and,
4. A gross floor area of 404.07sq m (approx. 4349.37sq ft) whereas By-law 0225-2007, as amended, permits a maximum gross floor area of 310.17sq m (approx. 3338.64sq ft) in this instance.

## Background

**Property Address:** 1460 Kenmuir Ave

### Mississauga Official Plan

Character Area: Mineola Neighbourhood  
Designation: Residential Low Density II

### Zoning By-law 0225-2007

**Zoning:** R3-1- Residential

**Other Applications: none**

### Site and Area Context

The subject property is located within the Mineola Neighbourhood Character Area, west of Cawthra Road and South Service Road. The neighbourhood is primarily residential, consisting of a mix of older and newer one and two storey-detached dwellings with significant mature vegetation in the front, rear and side yards. The subject property contains a one-storey single detached dwelling with mature vegetation in the front yard.

The application proposes a new two-storey detached dwelling requiring variances related to exterior side yard setback, heights and gross floor area.



## Comments

### Planning

Section 45 of the *Planning Act* provides the Committee of Adjustment with the authority to grant relief from the requirements of a municipal zoning by-law. Approval of applications must meet the requirements set out under 45(1) and/or 45(2) (a) or (b) in the *Planning Act*.

Staff comments concerning the application are as follows:

The subject property is located in the Mineola Neighbourhood Character Area and is designated Residential Low Density II in Schedule 10 of the Mississauga Official Plan (MOP). The Residential Low Density II designation permits detached, semi-detached, duplex, triplex, street townhouses and other forms of low-rise dwellings with individual frontages.

While larger dwellings are not out of character within the surrounding area, staff are of the opinion that the proposed gross floor area (GFA) is excessive. Furthermore, the GFA will create

a dwelling that does not meet the intent of the infill regulations, maintain compatibility with the existing dwellings in the neighbourhood or preserve the neighbourhood's existing character.

As such, staff recommend that the application be deferred to allow the applicant the opportunity to redesign the proposed dwelling.

Comments Prepared by: Connor DiPietro, Committee of Adjustment Planner

## Appendices

### Appendix 1 – Transportation and Works Comments

We are noting for Committee's information that any Transportation and Works Department concerns/requirements for the proposed dwelling will be addressed by our Development Construction Section through the future Building Permit process.









Comments Prepared by: John Salvino, Development Engineering Technologist

### **Appendix 2 – Zoning Comments**

We note that a Building Permit is required. In the absence of a Building Permit we are unable to confirm the accuracy of the information provided, or determine whether additional variance(s) may be required. It should be noted that a zoning review has NOT been completed.

The applicant is advised that should they choose to proceed without zoning verification, a full zoning review may result in further variances being required in the future.

Comments Prepared by: Candice Williams, Zoning Examiner

### **Appendix 3 – Region of Peel**

**Minor Variance: A-23-347M – 1460 Kenmuir Ave**

Development Engineering: Brian Melnyk (905) 791-7800 x3602

**Comments:**

- Please be advised that service connection sizes shall be in compliance with Ontario Building Code and Region of Peel Design Criteria. An upgrade of your existing service may be required. All works associated with the servicing of this site will be at the applicant's expense. For more information, please contact Servicing Connections at 905.791.7800 x7973 or by email at [siteplanservicing@peelregion.ca](mailto:siteplanservicing@peelregion.ca).
- All unutilized water and sanitary services shall be abandoned in accordance with Region of Peel design specifications. For more information, please contact Servicing Connections at 905.791.7800 x7973 or by email at [siteplanservicing@peelregion.ca](mailto:siteplanservicing@peelregion.ca).
- Any changes to the underground water or sanitary sewer will require review by the Region of Peel. Site Servicing approvals are required prior to the local municipality issuing building permit. For more information, please contact Servicing Connections at 905.791.7800 x7973 or by email at [siteplanservicing@peelregion.ca](mailto:siteplanservicing@peelregion.ca).

Comments Prepared by: Patrycia Menko, Junior Planner