

City of Mississauga Department Comments

Date Finalized: 2024-09-13	File(s): A409.24 Ward: 2
To: Committee of Adjustment	
From: Committee of Adjustment Coordinator	Meeting date:2024-09-19 1:00:00 PM

Consolidated Recommendation

The City has no objections to the application.

Application Details

The applicant requests the Committee to approve a minor variance to allow an addition proposing:

1. A garage attachment width to the dwelling of 3.36m (approx. 11.02ft) whereas By-law 0225-2007, as amended, requires a minimum attachment width to a dwelling of 5.00m (approx. 16.41ft) in this instance; and,
2. A garage area of 87.80sq m (approx. 945.08sq ft) whereas By-law 0225-2007, as amended, permits a maximum garage area of 75.00sq m (approx. 807.30sq ft) in this instance.

Background

Property Address: 1483 Randor Dr

Mississauga Official Plan

Character Area: Clarkson - Lorne Park Neighbourhood
Designation: Residential Low Density I

Zoning By-law 0225-2007


Zoning: R2-4 - Residential

Other Applications: Building Permit application BP 9ALT 24-1032

Site and Area Context

The subject property is located within the Clarkson – Lorne Park Neighbourhood Character Area, southeast of South Sheridan Way and Clarkson Road North intersection. The neighbourhood consists of newer and older one and two-storey detached dwellings. The subject property contains an existing one-storey detached dwelling with mature vegetation in the front yard.

The applicant is proposing an addition requiring variances for garage attachment width and garage area.



Comments

Planning

Section 45 of the *Planning Act* provides the Committee of Adjustment with the authority to grant relief from the requirements of a municipal zoning by-law. Approval of applications must meet the requirements set out under 45(1) and/or 45(2) (a) or (b) in the *Planning Act*.

Staff comments concerning the application of the four tests to this minor variance request are as follows:

Does the proposal maintain the general intent and purpose of the Official Plan?

The property is located in the Clarkson - Lorne Park Neighbourhood Character Area and is designated Residential Low Density I on Schedule 10 of the Mississauga Official Plan (MOP). This designation permits only detached dwellings in this instance. Section 9 of MOP promotes development with appropriate urban form and site design, regulating that such development is compatible with the existing site conditions, the surrounding context, and the landscape of the character area. Staff are of the opinion that the garage size does not impact the property's

permitted use and is compatible with existing use, site conditions and the surrounding context. The proposal therefore maintains the general intent and purpose of the official plan.

Does the proposal maintain the general intent and purpose of the Zoning By-law?

The applicant is proposing a garage addition. Variance #1 requests an increase in the garage attachment width and Variance #2 requests an increase in the garage area. The intent in restricting the size of an attached garage and garage attachment width is to ensure that the detached dwelling remains residential in nature and that the majority of the structure's ground floor area is attributed to livable space, rather than storage space. Additionally, this portion of the by-law serves to minimize the visual impact resulting from multiple, or excessive, garage faces facing the street from a streetscape perspective. Staff are of the opinion that the proposed increase is suitable in this instance and does not negatively impact the streetscape. Staff are satisfied that the garage is appropriately sized for both the lot and the dwelling.

Is the proposal desirable for the appropriate development of the subject lands and minor in nature?

The proposed dwelling maintains the existing and planned context of the surrounding area and does not pose a negative impact to the neighbourhood by maintaining the planned character of the neighbourhood. Staff are of the opinion that the application represents orderly development of the lands and is minor in nature.

Comments Prepared by: Shivani Chopra, Committee of Adjustment Planner

Appendices

Appendix 1 – Transportation and Works Comments

We are noting for Committee's information that any Transportation and Works Department concerns/requirements for the proposed addition are being addressed by our Development Construction Section through the Building Permit process, File BP 9ALT-24-1032.

Comments Prepared by: John Salvino, Development Engineering Technologist





Appendix 2 – Zoning Comments

The Building Division is processing Building Permit application BP 9ALT 24-1032. Based on the review of the information available in this application, the requested variance(s) is/are correct.

Our comments may no longer be valid should there be changes in the Committee of Adjustment application that have yet to be submitted and reviewed through the Building Division application. To receive updated comments, the applicant must submit any changes to information or drawings separately through the above application.

Comments Prepared by: Brooke Herczeg, Zoning Examiner

Appendix 3 – Parks, Forestry & Environment

The Forestry Section of the Community Services Department has reviewed the above noted minor variance application and advises as follows:

1. No public trees shall be injured or removed. If public tree injury or removal is required, a permit must be issued as per By-law 0020-2022.
2. No private trees shall be injured or removed. If a private tree with a diameter of 15 centimetres or greater on private property is to be injured or destroyed, a permit must be issued as per By-law 0021-2022.
3. Please note if a tree is identified as a shared tree with the adjacent property owner, and the applicant intends to apply for a Tree Removal Permit, written consent must be obtained by both parties.

A Tree Removal Application to Permit the Injury or Destruction of Trees on Public and Private Property can be found at <https://www.mississauga.ca/publication/application-to-permit-the-injury-or-destruction-of-trees-on-public-and-private-property/>.

Should further information be required, please contact Jamie Meston, Landscape Technician, Forestry Section, Community Services Department at 905-615-3200 ext. 4264 or via email jamie.meston@mississauga.ca.

Comments Prepared by: Jamie Meston, Landscape Technician

Appendix 4 – Region of Peel

Minor Variance Application: A-24-409M / 1483 Randor Drive

Development Engineering: Wendy Jawdek (905) 791-7800 x6019

Comments:

- Any changes to the underground water or sanitary sewer will require review by the Region of Peel. Site Servicing approvals are required prior to the local municipality issuing building permit. For more information, please contact Servicing Connections at 905.791.7800 x7973 or by email at siteplanservicing@peelregion.ca.

Comments Prepared by: Petrele Francois, Junior Planner